CCC - P67940 Page 1 of 1

PURAFIL ENVIRONMENTAL CORROSIVITY REPORT

18-Nov-2010

Company: 118628

Room/Area ID: Reference #:



 Sales Order #:
 C002697

 CCC Panel #:
 P67940

 Date In:
 20-Oct-2010

 Date Out:
 02-Nov-2010

Days In Service: 13

CCC Panel # P67940

ISA Class G2 Moderate

Copper Corrosion 396 Å/30 Days

Silver Corrosion 734 Å/30 Days

(see next page for complete analysis)

Summary for PURAFIL CCC # P67940

The electrolytic reduction analysis on Corrosion Classification Coupon #P67940 shows the presence of moderate concentrations of contaminants in the environment tested. The hydrogen sulfide level is expected to range between 3 and 10 ppb and the sulfur dioxide level between 10 and 100 ppb. The effects of corrosion are measurable and may be a factor in determining equipment reliability.

Your local representative for additional information and assistance is:

Environmental Health and Eng

117 Fourth Avenue, Needham MA 02494, USA

tminegishi@eheinc.com

Purafil, Inc. / 2654 Weaver Way, Doraville GA 30340 USA / (770) 662-8545 / (770) 263-6922 Email: purafil@purafil.com / Internet: http://www.purafil.com

Displaying Page 1 Display Page 2


CCC - P67940 Page 1 of 1

PURAFIL CCC # P67940 Analysis Results

Corrosion Film Composition Projections				Gold Coupon - Magnified 20x
	30 Days	1 Year	<u>5 Year</u>	magnifica 20x
Copper Films				
Cu ₂ S	o Å	0 Å	0 Å	
Cu ₂ O	138 Å	182 Å	238 Å	
Unknowns	258 Å	340 Å	445 Å	
Totals	396 Å	522 Å	683 Å	
Silver Films				
AgCI	0 Å	0 Å	0 Å	
Ag ₂ S	734 Å	8935 Å	44675 Å	
Unknowns	o Å	0 Å	0 Å	
Totals	734 Å	8935 Å	44675 Å	
Gold Pore Corrosion: Note: 1000 Å = 0.1 micron				

Equipment Reliability Correlation

(ISA Standard S71.04-1985 for Copper)



Displaying Page 2 <u>Display Page 1</u>